

A: Parking and Passenger Loading Zones

(Attach Needed Survey Forms to this Summary Sheet.)

Parking - Minimum Number: 4.1.2(5)(a) and (b)

General Use Parking: If self parking is provided for employees or visitors, each parking area/lot or structure is required to have accessible parking spaces complying with the following table and with 4.6.

Note: Spaces required by the table need not be provided in the particular area/lot or structure. They may be provided at a different location if equivalent or greater accessibility, in terms of distance from an accessible entrance, cost and convenience, is ensured.

Total Parking in Area/Lot or Structure	Required Minimum Number of Accessible Spaces
1 to 25	1
26 to 50	2
51 to 75	3
76 to 100	4
101 to 150	5
151 to 200	6
201 to 300	7
301 to 400	8
401 to 500	9
501 to 1000	2 percent of total
1001 and over	20 plus 1 for each 100 over 1000

In addition, one in every eight accessible parking spaces (but not less than one) must be served by an access aisle at least 96 inches wide and must be designated "van accessible."

Exception: Provision of all required spaces in conformance with the "Universal Parking Space Design" which accommodates both cars and vans is permitted (see Appendix A4.6.3 of ADAAG).

Parking at Health Care Facilities: 4.1.2(5)(a), (b) and (d)

Employee and visitor parking at general health care facilities must comply with the table above, except as follows. At outpatient units and facilities, 10 percent of the total number of parking spaces provided serving each such outpatient unit or facility must be accessible. At units and facilities specializing in treatment or services for people with mobility impairments, 20 percent of the total number of spaces provided serving each such unit or facility must be accessible.

List parking areas/lots or structures to be surveyed:

Survey each parking area/lot or structure with Form 1: Parking and Passenger Loading Zones and Form 3: Exterior Accessible Routes. For parking structures which have doors or gates, or elevators, use Form 11: Doors and Gates and Form 13: Elevators. If direct access is provided for pedestrians from an enclosed parking garage to a building, use Form 10: Entrances and Exits (Areas of Rescue Assistance). If the parking structure has public telephones or drinking fountains, use Form 5: Drinking Fountains and Form 6: Telephones. If the parking structure has toilet rooms, use Minimum Requirements Summary Sheet F: Toilet Rooms and Bathrooms.